

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7150-2010:0504

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Model FIK-W-PULL-DA Wireless Manual Pull Station, non-coded, addressable, single action, intended for indoor use only. Surface mounted to a separately listed back box or flush mounted to a separately listed embedded box.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3.3 VDC:
(4) Panasonic CR123A Batteries
(4) Duracell DL123A Batteries
Alarm current - 5.0 mA
Standby current - 210 uA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as fire alarm pull boxes for use with separately listed compatible fire alarm control units. Model FIK-W-PULL-DA is intended for indoor use, surface or flush mount when installed with separately listed back box. Two year minimum battery life. Batteries to be replaced when "TROUBLE BATTERY LOW" display and/or during annual maintenance. Refer to listee's Installation Instruction Manual for details.

These manual pull boxes meet the requirements of UL Standard 38.

XLF: 7150-0028:0504

3-25-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division