

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-2010:0523

Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Model FCP-75 Fire Alarm Control Unit, automatic, manual, local, remote station (PPU), central station (PPU), releasing (water deluge only).

Model FCP-75 System Components:

*FIK-RA1000R - Remote Annunciator
FIK-5496 - NAC Expander
FIK-5880 - LED I/O Module
FIK-5865-3 - Remote LED Annunciator
FIK-5865-4 - Remote LED Annunciator
FIK-5883 - Relay Interface
FIK-5824 - Serial/Parallel Printer Interface Module
FIK-NIC - Network Interface Card
FIK-NIC-KIT - Network Interface Card in Cabinet
FIK-FML - Multi Mode Fiber Card
FIK-FSL - Single Mode Fiber Card
RBB - Remote Battery Box (16"W x 10"H x 6"D)

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Primary Operating Power Supply:
120VAC, 60Hz, 1.5A

Secondary Operating Power Supply:
24VDC, 3.1A, 35Ah

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a commercial fire alarm control unit for use with separately listed initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

XLF: 7165-0559:0503

*Revision 8-13-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division