

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7254-2010:0509

Page 1 of 1

**CATEGORY:** 7254 -- HEAT DETECTOR (SINGLE/MULTIPLE)

**LISTEE:** FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013  
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082  
Email: brent.mlika@fike.com

**DESIGN:** Models FIK-W-HEAT and FIK-W-HEAT-ROR Electronic Fixed Temperature Heat Detectors.  
Model FIK-W-HEAT is a 135°F electronic fixed temperature heat detector. Model FIK-W-HEAT-ROR is a 135°F electronic fixed temperature heat detector with 15°F/min rate-of-rise.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 3.2 Vdc lithium battery, Panasonic Type CR123A or Duracell Type DL123A. Four batteries are used in parallel connection.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as electronic fixed temperature heat detectors for use with System Sensor bases Models B210W and B501W (CSFM Listing No. 7300-1653:0233) and separately listed compatible fire alarm control panels. Refer to listee's Installation Instruction Manual for details.

**XLf:** 7254-0028:0270

3-25-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

*Fire Engineering Division*