

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-2010:0505 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Models FIK-CR-6 relay module, FIK-SC-6 supervising control module, FIK-IM-10 input monitor module, FIK-CZ-6 six zone interface module, FIK-M500M, FIK-M501M, FIK-M502M, FIK-M500DM monitor modules, FIK-M500S, FIK-M500R control modules, and FIK-M500MR-2 with 2 input/2 output relay module. All devices are intended to be connected between the signaling line circuit of a compatible fire alarm control panel.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC Primary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: If an external power supply is used for Model FIK-CZ-6, the negative of the external power supply is referenced to the negative of the auxiliary supply of the compatible control panel. This is done in order to detect ground faults on the initiating circuit.

XLF: 7300-0028:0219

3-25-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division