

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-2010:0506 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Model FIK-M500X Fault Isolator Module.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 15-32 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7300-0028:0261

3-25-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division