

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-2010:0503

Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Models FIK-PULL-DA and FIK-PULL-SA fire alarm pull boxes. Units are dual action, N/O contacts, key lock, and utilizes addressable module. The outer housing and back plate are constructed of plastic for securing the station to a back box. Intended for indoor use only and are intended to be mounted to a Listed outlet box or with Models WP-10, SB-I/O, or WBB back box.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 Vdc, 300 uA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as fire alarm pull boxes for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

These manual pull boxes meet the requirements of UL Standard 38 and California amendments which the controls and operating mechanisms required to be operable at no more than 5 lbs force with one hand and shall not require tight grasping, pinching, or twisting of the wrist.

XLf: 7150-0028:0199

3-22-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division