50 Point Dead-Front Panel
Installation Instructions

DESCRIPTION

The 50 point dead-front panel (See Exhibit 1) is made of 16 gauge steel with a baked on enamel finish (red or black). It is designed to isolate the operator from interior electronics and wiring, yet allows easy access to system control buttons. The dead-front panel can be easily removed for service or maintenance purposes.

Dead-front Panel

Part Number: 10-2628-c (CyberCat™ or Cheetah™ Xi)
Weight: 5 lbs. (2.3 kg)

SUPPLIED MOUNTING HARDWARE

The following mounting hardware is supplied with the dead-front panel for installation:

02-11779   Dead-front Bezel

02-11082   Hardware Kit (qty. 2)
           #10 Lock Washer (qty. 2)
   #10-32 x .375 Self-tapping Screw

Exhibit 1: Dead-Front Panel

INSTALLATION

Install the dead-front panel only after all electronics have been installed in the enclosure and the system has been fully tested and commissioned.

1. Unpack the dead-front panel components and check for signs of shipping damage. Package should include following items:

    a. Dead-front panel
    b. Display bezel
    c. Self-tapping screws (qty. 4)

2. Align the dead-front display bezel with the opening in the dead-front panel and snap into place.

3. Align the dead-front panel mounting tabs with the mounting holes provided in the enclosure back-box and secure in place using the four (4) self-tapping screws provided.

4. Adjust routing of outer door grounding wire through slot supplied in dead-front panel.

Exhibit 2: Dead-front Panel Assembly