

DoP 326-0023-R

| | |
|---|-------------------|
| 1. Unique Product identification code: | |
| Sita Sounder Strobe with Short Circuit Isolator (Deep Base) | 326-0023-R |
| 2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4): | |
| 326-0023-R | |
| 3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer: | |
| Fire detection and fire alarm systems installed in and around buildings. (For indoor use only). | |
| 4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5): | |
| Fike Safety Technology Ltd. Unit 31, Springvale Industrial Estate Cwmbran, Torfaen NP44 5BD, United Kingdom | |
| 5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2): | |
| Not applicable | |
| 6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: | |
| System 1 | |
| 7. In case of the declaration of performance concerning a construction product covered by a harmonised standard: | |
| <p align="center">BRE Global Ireland – 2831 BRE Global UK - 0832</p> <p>Performed type testing and an inspection of the manufacturing plant and of factory production control under system 1 and issued following certificate of constancy of performance:</p> <p align="center">2831 – CPR – F4125 0832-UKCA-CPR-F0732</p> | |
| 8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: | |
| Not applicable, see point 7 | |

Unit 31 Springvale Industrial Estate | Cwmbran NP44 5BD, United Kingdom | 0044 1633 865 558

| 9.Declared Performance | | | |
|--|-------------|------------------------------------|-----------------|
| Essential characteristics | Performance | Harmonised technical specification | |
| | | EN54 - 3: 2014 +A1: 2019 | EN54 - 17: 2005 |
| Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions | Pass | 4.2, 4.3, 5.2, 5.3 | |
| Operational reliability | Pass | 4.4, 4.5, 4.6, 5.4 | 4.2 to 4.9 |
| Tolerance to supply Voltage | | | |
| Durability of operational reliability and response delay, Temperature resistance | Pass | 5.5, 5.7, 5.8, 5.9 | 5.4, 5.5 |
| Durability of operational reliability, Vibration resistance | Pass | 5.2 to 5.15 | 5.9 to 5.12 |
| Durability of operational reliability, Humidity resistance | Pass | 5.8, 5.9 | 5.6, 5.7 |
| Durability of operational reliability, Corrosion resistance | Pass | 5.11 | 5.8 |
| Durability of operational reliability, Electrical stability | Pass | 5.16 | 5.3, 5.13 |
| Performance under fire conditions | Pass | | 5.2 |
| Durability of operational reliability: Resistance to ingress | Pass | 5.17 | |
| <p>10. The performance of the product Identified in points 1 & 2 is in conformity with the declared performance in point 9.</p> <p>This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.</p> <p>Signed for and on behalf of the manufacturer by:</p> <p>(Name and Function). Mark Kendall – General Manager (Place and date of issue) Fike Safety Technology Ltd. Cwmbran 16th Feb 24 (Signature) <i>Mark Kendall</i></p> | | | |