



Certificate of Compliance

Certificate: 1616749

Master Contract: 159130

Project: 1616749

Date Issued: 2005/02/25

Issued to: **Fike Corporation**
704 South 10th St
Blue Springs, MO 64013
USA
Attention: Richard Dunn

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ana Adari P.Eng.

Authorized by: Gabriel Lippa, C.E.T., Product
Group Manager

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Control units, open type, Series EPC, Model E10-0066, Input 18-30V dc, output, 0-42V dc, 1A (ac), relay dry contacts, 2A res, 24V dc and 0.5A, 250V ac.

Control units, open type, Series RC8, Model E10-0069, Input 24V dc, 300mA output. 6 circuits, 24V dc, 1A (ac), 8 relay dry contacts 4A res, 24V dc.

Control units, open type, Series AM, Model E10-0068, Input 18-30V dc, 500mA max controls, relay dry contact 4A res, 24V dc.

Note: Open-type equipment is certified only for use in complete assemblies where the suitability of the



Certificate: 1616749

Master Contract: 159130

Project: 1616749

Date Issued: 2005/02/25

combination is to be determined.

APPLICABLE REQUIREMENTS

C22.2 No.14-95 (R2001) - Industrial Control Equipment



Supplement to Certificate of Compliance

Certificate: 1616749

Master Contract: 159130

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1616749	2005/02/25	EPC, RC8 and AM Controllers