

DOP 326-0021

1. Unique Product identification code:	
Sita Sounder with Short Circuit Isolator (Low Profile Base)	326-0001
2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):	
326-0001	
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:	
Fire detection and fire alarm systems installed in and around buildings. (For indoor use only).	
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):	
Fike Safety Technology Ltd. Unit 31, Springvale Industrial Estate Cwmbran, Torfaen NP44 5BD, United Kingdom	
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):	
Not applicable	
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:	
System 1	
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:	
BRE Global Ireland – 2831 Performed type testing and an inspection of the manufacturing plant and of factory production control under system 1 and issued following certificate of constancy of performance: 2831 – CPR – F4122	
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:	
Not applicable, see point 7	

9.Declared Performance			
Essential characteristics	Performance	Harmonised technical specification	
		EN54 - 3: 2001 +A1: 2002 +A2: 2006	EN54 - 17: 2005
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	4.2, 4.3, 5.2, 5.3	
Operational reliability	Pass	4.4, 4.5, 4.6, 5.4	4.2 to 4.9
Tolerance to supply Voltage			
Durability of operational reliability and response delay, Temperature resistance	Pass	5.5, 5.7, 5.8, 5.9	5.4, 5.5
Durability of operational reliability, Vibration resistance	Pass	5.2 to 5.15	5.9 to 5.12
Durability of operational reliability, Humidity resistance	Pass	5.8, 5.9	5.6, 5.7
Durability of operational reliability, Corrosion resistance	Pass	5.11	5.8
Durability of operational reliability, Electrical stability	Pass	5.16	5.3, 5.13
Performance under fire conditions	Pass		5.2
Durability of operational reliability: Resistance to ingress	Pass	5.17	

10. The performance of the product Identified in points 1 & 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of the manufacturer by:

(Name and Function) Mark Kendall – General Manager

(Place and date of issue)

(Signature) 

Fike Safety Technology Ltd. Cwmbran 12th Feb 20